

**CETEC**

Professional Scientific Solutions

Emission Test Certificate

Wednesday, 2nd February 2011

Supplier: GRM Australia (Unit 2, 74-80 Helen St, Sefton, NSW, 2162)

Sample Description: BioWood

Date Tested: January 2011

Emission Data:

Green Building Council of Australia Green Star Specification	BioWood
Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".	
Office Design V2 IEQ-13 < 0.5 mg/m ² /hr (24 hours) Office Design V3 IEQ-13 < 0.5 mg/m ² /hr (24 hours)	<0.01 mg/m ² /hr (VOC) When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.25 mg/m ³ .
Test Method: EN717-2 "Wood-based Panels - Determination of Formaldehyde Release - Part 2: Formaldehyde Release by the Gas Analysis Method".	
	0.03 mg/m ² /hr (Formaldehyde)

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV101202